

# Detailed Latest Test Results



Test Status: All, Test Type: All  
Person: All, Instrument: All  
From: 06/09/2023 To: 06/09/2023

**Client: Crazy 9.**

**Site: Crazy 9**

<b>Location: Events</b>				
Asset ID: 62392	Description: Power Lead	User: C Kennedy	Test Instrument: Seaward Apollo 500 Plus 25J-0387	

Comments:

Test Type	Date	Result	Unit	Status
Plug	06/09/2023			Pass
Flex	06/09/2023			Pass
Enclosure	06/09/2023			Pass
Environment	06/09/2023			Pass
Socket	06/09/2023			Pass
Switch	06/09/2023			Pass
Voltage	06/09/2023	230	V	Information
Insulation Voltage	06/09/2023	500	V	Information
Insulation	06/09/2023	> 19.99	MOhm	Pass
				<b>Overall: Pass</b>

Asset ID: 62393	Description: Television	User: C Kennedy	Test Instrument: Seaward Apollo 500 Plus 25J-0387	
-----------------	-------------------------	-----------------	---	--

Comments:

Test Type	Date	Result	Unit	Status
Plug	06/09/2023			Pass
Flex	06/09/2023			Pass
Enclosure	06/09/2023			Pass
Environment	06/09/2023			Pass
Socket	06/09/2023			Pass
Switch	06/09/2023			Pass
Voltage	06/09/2023	230	V	Information
Insulation Voltage	06/09/2023	500	V	Information
Insulation	06/09/2023	> 19.99	MOhm	Pass
				<b>Overall: Pass</b>

Asset ID: 62394	Description: Battery Charger	User: C Kennedy	Test Instrument: Seaward Apollo 500 Plus 25J-0387	
-----------------	------------------------------	-----------------	---	--

Comments:

Test Type	Date	Result	Unit	Status
Plug	06/09/2023			Pass
Flex	06/09/2023			Pass
Enclosure	06/09/2023			Pass
Environment	06/09/2023			Pass
Socket	06/09/2023			Pass
Switch	06/09/2023			Pass
Voltage	06/09/2023	230	V	Information
Insulation Voltage	06/09/2023	500	V	Information
Insulation	06/09/2023	> 19.99	MOhm	Pass
				<b>Overall: Pass</b>

# Detailed Latest Test Results



Test Status: All, Test Type: All  
Person: All, Instrument: All  
From: 06/09/2023 To: 06/09/2023

Asset ID: 62395	Description: Extension Lead	User: C Kennedy	Test Instrument: Seaward Apollo 500 Plus 25J-0387
-----------------	-----------------------------	-----------------	---

Comments:

Test Type	Date	Result	Unit	Status
Plug	06/09/2023			Pass
Flex	06/09/2023			Pass
Enclosure	06/09/2023			Pass
Environment	06/09/2023			Pass
Socket	06/09/2023			Pass
Switch	06/09/2023			Pass
Voltage	06/09/2023	230	V	Information
IEC Lead Continuity	06/09/2023	0.22	ohm	Pass
Insulation Voltage	06/09/2023	500	V	Information
Insulation	06/09/2023	> 19.99	MOhm	Pass
IEC Lead Polarity	06/09/2023			Pass

Overall: Pass

Total Tests: 4